



Technology that saves lives

# Smoke! in a Can<sup>®</sup>

## Aerosol Spray for Functional Testing of Smoke Detectors



### Overview

NFPA 72, Table 7.2.2, states that “detectors shall be tested in place to ensure smoke entry into the sensing chamber and an alarm response.” Smoke! in a Can<sup>®</sup> lets you meet this requirement without contaminating the detector, without affecting its sensitivity, and without increasing the risk of false alarms.

#### *Patented formula evaporates completely*

Smoke! in a Can is UL listed for all brands and models of photoelectric or ionization type smoke detectors. Its safe, non toxic formula contains no CFCs. After verifying smoke entry into the detector, you can walk away assured that Smoke! in a Can will evaporate completely, eliminating the build up of left over contaminants found in other smoke test formulas.

### Standard Features

- Meets NFPA functional test requirements
- Does not contaminate detector
- Evaporates completely
- Non-toxic formula with no CFCs
- MSDS sheet on back of easy-to-peel-off label
- Optional tube available to snap on can slows down aerosol and ensures can is held proper distance away from smoke detector



Technology that saves lives

Contact us...

Email: [kidde.fire@fs.utc.com](mailto:kidde.fire@fs.utc.com)

Web: [Kidde.com/EngineeredSystems](http://Kidde.com/EngineeredSystems)

Kidde is a UTC brand.  
1016 Corporate Park Drive  
Mebane, NC 27302

© 2016 United Technologies Corporation.  
All rights reserved.

## Warnings & Cautions

Extremely Flammable. Contents under pressure.

Potential health effects:

- Inhalation: High vapor concentration may cause drowsiness and irritation.
- Eyes & Skin: Irritation. Prolonged or repeated exposure may cause drying, cracking or irritation.

## Handling & Storage

Store in a cool, dry area. Aerosol cans must be maintained below 120°F to prevent cans from exploding. Note: always hold the can 2 feet from smoke detector and spray 2-3 short bursts of aerosol at the detector to create a cloud of particles around detector. A constant spray of the aerosol too close will blow the spray through detector potentially not causing detector to not alarm.

## Properties

Physical State	Liquid
Specific Gravity	.81
Appearance & Odor	Colorless liquid alcohol odor
Boiling Point	172°F (initial)
Vapor Density (air=1)	1.6 (est.)
Solubility	Appreciable in H <sub>2</sub> O

Note: MSDS sheet on back of easy to peel off Smoke! in a Can label

## Ordering Information

Model Number	Description
SM200 -12PKG	Smoke! in a Can aerosol spray for functional testing of smoke detectors, case of 12 cans
SM-EXT1	Extension tube snaps on Smoke! in a Can to slow down aerosol spray puffs helping to create a cloud of particles around detector